## South San Joaquin Irrigation District

# ADDENDUM NO.2

PROJECT: SSJID-24007-Lateral X-W Pipeline Connection Project

TO: All Plan holders of Record

FROM: South San Joaquin Irrigation District

BID DATE: Thursday, September 12<sup>th</sup>, 2024, 2:00PM PST

Notice is hereby given to prospective bidders that the Bid Documents for the Lateral X-W Pipeline Connection Project have been modified as hereinafter set forth. <u>This Addendum No.2 shall form a part of the Bid Documents and takes precedence over the original Bid Documents.</u>

The following revisions, additions, or deletions shall be made to the Contract Documents:

### **REVISION: Bid Date**

The bid date shall be Thursday, September 12th, 2024 at 2:00PM PST.

#### **ADDITION: Second Mandatory Pre-Bid Meeting**

Due to an error with the local builder's exchange posting after the mandatory pre-bid meeting held on 8/14/2024. A second mandatory pre-bid meeting will be held on August 28<sup>th</sup>, 2024 at 10:00am PST at the SSJID Main Office at 11011 E. Highway 120 Manteca, Ca 95366 for prospective bidders. Bidders who attended the mandatory pre-bid meeting held on 8/14/2024 will not be required to attend the second pre-bid meeting but may do so if they wish. The second mandatory pre-bid meeting will be identical in substance as the first. Any bidders who have already submitted a bid have the right to retract their bid and resubmit prior to the new bid opening date and time.

#### REVISION: Remove 45' Easement Labels on Sheets C4 & C5


Revision to plan Sheet C4, remove label stating "45' Wide Easement +/-12,136 SF" within APN 226-130-340 and Sheet C5, remove label stating "45' Wide Easement +/-39,517SF" (See attached revised plan sheets)

Bidders shall acknowledge receipt of Addendum No.2 in the space below and include this page with the bid. Failure to do so may subject bidder to disqualification.

Chad Parsons P.E. Associate Engineer

I acknowledge receipt of Addendum No.2, consisting of three (3) pages.

Signed\_\_\_\_\_Bidder





100% DESIGN RIDDING PURPOSES ( 08/02/2024

SAN JOAQUIN IRRIGATION DISTR SAN JOAQUIN COUNTY CIVIL - PLAN & PROFILE

PROVOST& PRITCHARD 4701 SISK ROAD, SUITE 102

DESIGN ENGINEER: ED CAMINATA LICENSE NO:


88473 DRAFTED BY: CHECKED BY: LAJ, JMG ACC


DATE: 08/02/2024 JOB NO: 105522007 PROJECT NO: 105522007

PHASE: PRE ORIGINAL SCALE SHOWN IS ONE INCH. ADJUST SCALE FOR

REDUCED OR ENLARGED PLANS.


10 of 16






- RECONNECT OR RELOCATE (E) PRIVATE IRRIGATION PIPELINES.
- 2. PIPELINE BENDS SHALL BE CONSTRUCTED IN THE FIELD USING CONCRETE COLLARS PER DETAIL 4 SHEET CD1. USE OF PRECAST ELBOW FITTINGS SHALL BE INCLUDED AS ALTERNATE BID ITEMS.
- 3. PIPELINE SHALL BE ASTM C-76 CL III RUBBER GASKETED REINFORCED CONCRETE PIPE.
- 4. WATERMAN CANAL GATES, GRATING, RAILING, LADDERS, AND STEPS AT CONTROL BOXES ARE TO BE FURNISHED AND INSTALLED BY THE OWNER. VENT COVERS ARE TO BE FURNISHED AND INSTALLED BY THE OWNER.

30+00 HGL 42.52 PHASE 1 & 2	31+00	32+00	33+00	34+00	35+00	36+00	37+00	38+00	39+00	40+00
PHASE 1 & 2								+		
HGL 42.50 PHASE 1	) & 2				F&I ACCESS AIR VENT	HGL 42.00 PHASE 1 & 2 HGL 42.10 PHASE 1 & 3				HGL 41.81 PHASE 1 & 2
(E) PRIVATE PROTECTE TO FIELD V INFORM SS IF WELL PIF X-W PIPELII	E WELL PIPELINE TO BE D IN PLACE. CONTRACTOR ERIFY ELEVATION AND JID ENGINEER IMMEDIATELY PELINE CONFLICTS WITH (P) NE ELEVATIONS AND RELOCATE (E) 12" PVC AND (E)				30" MIN. COVER	8" SD INV 41.5± (	(6.06)	STORM WATER PUMP PIPING TO W190		40
MIN	C PRIVATE PIPELINES. PROVIDE 1' SEPARATION OVER OR UNDER (P) RGRCP AND (P) 24" STEEL PIPE						(BY OWNER)  48" INV 30.50 (W)			35
INV 28.5	50		S=0.	0000		(E) 42" CIPP INV 31.47		S=0.0004		INV 30.38
INV 28.50										25
					F&I 1000 LF OF 48" RGRCP					20








RECONNECT OR RELOCATE (E) PRIVATE

- 2. PIPELINE BENDS SHALL BE CONSTRUCTED IN THE FIELD USING CONCRETE COLLARS PER DETAIL 4 SHEET CD1. USE OF PRECAST ELBOW FITTINGS SHALL BE INCLUDED AS ALTERNATE
- PIPELINE SHALL BE ASTM C-76 CL III RUBBER GASKETED REINFORCED CONCRETE PIPE.
- WATERMAN CANAL GATES, GRATING, RAILING, LADDERS, AND STEPS AT CONTROL BOXES ARE TO BE FURNISHED AND INSTALLED BY THE OWNER. VENT COVERS ARE TO BE FURNISHED

100% DESIGNEDING PURPC 08/02/2024



SOUTH SAN JOAQUIN IRRIGATION DISTR SAN JOAQUIN COUNTY CIVIL - PLAN & PROFILE LATERAL X-W CONNECTION

DESIGN ENGINEER: ED CAMINATA LICENSE NO: 88473

DRAFTED BY: CHECKED BY: LAJ, JMG ACC

DATE: 08/02/2024 JOB NO: 105522007

PROJECT NO: 105522007 PHASE: PRE

ORIGINAL SCALE SHOWN IS ONE INCH. ADJUST SCALE FOR REDUCED OR ENLARGED PLANS.

11 of 16