

9/10/2024

South San Joaquin Irrigation District

NOTICE TO PLANHOLDERS
ADDENDUM NO.3

PROJECT: SSIJID-24007-Lateral X-W Pipeline Connection Project

TO: All Plan holders of Record

FROM: South San Joaquin Irrigation District

BID DATE: Thursday, September 12th, 2024, 2:00PM PST

Notice is hereby given to prospective bidders that the Bid Documents for the Lateral X-W Pipeline Connection Project have been modified as hereinafter set forth. This Addendum No.3 shall form a part of the Bid Documents and takes precedence over the original Bid Documents.

The following revisions, additions, clarifications, or deletions shall be made to the Contract Documents:

ADDITION: RGRCP Designation

ASTM C76 and ASTM C361 are both adequate for RGRCP for the Project. It is the Contractor's discretion to choose depending on availability. This includes rubber gaskets meeting ASTM C361 or ASTM C443.

CLARIFICATION: Project Completion Date

Additional working days or project extension will not be permitted past February 1st, 2025. The landowners involved in the project need the project completed and their private irrigation systems re-established for frost protection.

Bidders shall acknowledge receipt of Addendum No.3 in the space below and include this page with the bid. Failure to do so may subject bidder to disqualification.



Chad Parsons P.E.
Associate Engineer

I acknowledge receipt of Addendum No.3, consisting of one (1) page.

Signed _____

Bidder